

Ti-Sales Field



Town of Sudbury ADA Transition Plan

December 2020



Institute for Human Centered Design

200 Portland Street, Boston, MA 02114
www.IHCDesign.org • info@IHCDesign.org
617-695-1225 voice/ tty

Background

Ti-Sales field is located behind the Ti-Sales building at 36 Hudson Road. The field can be used for soccer, lacrosse, and ultimate Frisbee.

There is a large unpaved parking lot south of the field that has no accessible parking spaces.

Key Accessibility Issues

Exterior Access Routes

There is no accessible route between the parking lot and the field.

Parking Lot

No accessible parking spaces are provided. Based on an estimate of 112 parking spaces, one van accessible and four car accessible parking spaces are required.

Order of Magnitude Cost Estimates


- Provide an accessible route between the parking lot and the field: \$2,240
- Provide accessible parking spaces: \$4,000

Total: \$6,240



Best Practice and Inclusive Design

Best practice and inclusive design recommendations include elements that are not required in the standards but may create enhanced experiences for all users.

- The following image is based on the Massachusetts Department of Conservation and Recreation (DCR) Pocket Guide. It shows a suggested method of designating an access aisle in an unpaved parking lot.



**Town of Sudbury
Ti-Sales Field**

ID	Location	Floor	Room	Element	Type	Photo	Issues	Current Measure	Recommendations	Quantity	Price	Cost Estimation
1	Parking Lot	Ext.		Off-Street Parking Lot or Garage	N/A		Total # of parking Total # of designated accessible parking spaces	112 est. 0	Based on 112 estimated parking spaces, provide four (4) car accessible parking spaces and one (1) van accessible parking space.	5	800	\$4000
2	Route from Parking Lot to Field	Ext.		Exterior Access Route	Exterior		Accessible route not provided	-	Ensure an accessible route is provided. (Cost estimate for a 70' long, 4' wide stone dust route.)	1	2240	\$2240