

**Town of
Sudbury: Priority
for ADA
Transition Plan -
Schools**

Column14

11	Curtis Middle School	H. Emergency Exit	A. Tactile sign not provided at emergency exit B. Tactile sign not provided at exit	Egress Door 9	1	N/A	Priority 2	Navigational Issue	Provide tactile exit signs with raised characters and braille at exit doors. Mount signs between 48" - 60" above the finished floor located on the latch side of the door.	1			
12	Curtis Middle School	H. Emergency Exit	B. Tactile sign not provided at exit	Egress Door 5	1	N/A	Priority 2	Navigational Issue	Provide tactile exit signs with raised characters and braille at exit doors. Mount signs between 48" - 60" above the finished floor located on the latch side of the door.	1			
13	Curtis Middle School	H. Emergency Exit	B. Tactile sign not provided at exit D. Illuminated Int. Symbol of Acc. not provided (MAAB)	Main Entrance - Egress Door 1	1	N/A	Priority 2	Navigational Issue	Provide tactile exit signs with raised characters and braille at exit doors. Mount signs between 48" - 60" above the finished floor located on the latch side of the door. Provide an illuminated sign with the International Symbol of Accessibility.	1	Y	7/17/2023	FY24
14	Curtis Middle School	H. Emergency Exit	B. Tactile sign not provided at exit D. Illuminated Int. Symbol of Acc. not provided (MAAB)	Egress Door 4	1	N/A	Priority 2	Navigational Issue	Provide tactile exit signs with raised characters and braille at exit doors. Mount signs between 48" - 60" above the finished floor located on the latch side of the door. Provide an illuminated sign with the International Symbol of Accessibility.	1	Y	7/17/2023	FY24
37	Curtis Middle School	H. Signage	B. Raised characters not provided on sign D. Braille not provided on sign	Cafeteria	1	N/A	Priority 2	Navigational Issue	Provide text with raised characters duplicated in braille on sign.	1			
38	Curtis Middle School	H. Signage	B. Raised characters not provided on sign D. Braille not provided on sign	Auditorium/ Gymnasium Doorway	1	N/A	Priority 2	Navigational Issue	Provide text with raised characters duplicated in braille on sign.	1			
39	Curtis Middle School	H. Signage	B. Raised characters not provided on sign D. Braille not provided on sign	Technology Center	2	N/A	Priority 2	Navigational Issue	Provide text with raised characters duplicated in braille on sign. (Ensure signs are up-to-date and that accurate raised characters and braille are provided.)	1			
40	Curtis Middle School	H. Signage	D. Braille not provided on sign	Kitchen	1	N/A	Priority 2	Navigational Issue	Provide braille on sign.	1			
41	Curtis Middle School	H. Signage	D. Braille not provided on sign	Men's Toilet Room	1	N/A	Priority 2	Navigational Issue	Provide braille on sign.	1			
42	Curtis Middle School	H. Signage	G. Sign not located on the latch side of the door	Custodian	1	N/A	Priority 2	Navigational Issue	Locate sign at permanent rooms alongside the door on the latch side.	1			
43	Curtis Middle School	H. Signage	G. Sign not located on the latch side of the door	Grade 8 Bridges Program	1	106	Priority 2	Navigational Issue	Locate sign at permanent rooms alongside the door on the latch side.	1			
44	Curtis Middle School	H. Signage	G. Sign not located on the latch side of the door	Grade 8 Green SS	1	115	Priority 2	Navigational Issue	Locate sign at permanent rooms alongside the door on the latch side.	1			
45	Curtis Middle School	H. Signage	G. Sign not located on the latch side of the door	Grade 7 SpED LEAP	2	206	Priority 2	Navigational Issue	Locate sign at permanent rooms alongside the door on the latch side.	1			
79	Curtis Middle School	D. Toilet Compartment	D. Door has malfunctioning self-closing hinge	Men's Toilet Room	1	N/A	Priority 3	Additional Access	Repair hinge.	1			
80	Curtis Middle School	D. Toilet Compartment	D. Door has malfunctioning self-closing hinge	Men's Locker Room Accessible Compartment	1	N/A	Priority 3	Additional Access	Repair hinge.	1			
81	Curtis Middle School	D. Toilet Compartment	D. Door has malfunctioning self-closing hinge	Women's Toilet Room Near Cafeteria and Locker Rooms	1	N/A	Priority 3	Additional Access	Repair hinge.	1			
82	Curtis Middle School	D. Toilet Compartment	D. Door has malfunctioning self-closing hinge	Men's Toilet Room Near Cafeteria and Locker Rooms	1	N/A	Priority 3	Additional Access	Repair hinge.	1			
83	Curtis Middle School	D. Toilet Compartment	D. Door has malfunctioning self-closing hinge	Women's Toilet Room Section A	1	N/A	Priority 3	Additional Access	Repair hinge.	1			
84	Curtis Middle School	D. Toilet Compartment	D. Door has malfunctioning self-closing hinge	Men's Toilet Room	3	N/A	Priority 3	Additional Access	Repair hinge.	1			
85	Curtis Middle School	D. Toilet Compartment	D. Door has malfunctioning self-closing hinge	Women's Toilet Room	3	N/A	Priority 3	Additional Access	Repair hinge.	1			
86	Curtis Middle School	D. Toilet Compartment	D. Door has malfunctioning self-closing hinge	Women's Toilet Room	2	N/A	Priority 3	Additional Access	Repair hinge.	1			
87	Curtis Middle School	D. Toilet Compartment	D. Door has malfunctioning self-closing hinge	Men's Toilet Room	2	N/A	Priority 3	Additional Access	Repair hinge.	1			
88	Curtis Middle School	D. Toilet Compartment	D. Door has malfunctioning self-closing hinge	Men's Toilet Room	2	N/A	Priority 3	Additional Access	Repair hinge.	1			
89	Curtis Middle School	D. Toilet Compartment	D. Door has malfunctioning self-closing hinge	Women's Toilet Room	2	N/A	Priority 3	Additional Access	Repair hinge.	1			
90	Curtis Middle School	D. Toilet Compartment	M. Flush control not on open side	Women's Locker Room	1	N/A	Priority 3	Additional Access	Provide the flush control on the open side of the toilet (transfer side).	1			
91	Curtis Middle School	D. Toilet Compartment	M. Flush control not on open side	Women's Toilet Room Near Cafeteria and Locker Rooms	1	N/A	Priority 3	Additional Access	Provide the flush control on the open side of the toilet (transfer side).	1			
92	Curtis Middle School	D. Toilet Compartment	M. Flush control not on open side	Women's Toilet Room	2	N/A	Priority 3	Additional Access	Provide the flush control on the open side of the toilet (transfer side).	1			

93	Curtis Middle School	D. Toilet Compartment	N. Non-compliant toilet paper dispenser	Women's Toilet Room	3	N/A	Priority 3	Additional Access	Relocate toilet paper so that it is 24" min. high, located under the grab bar, and between 7" and 9" from the front of the toilet./Replace dispenser as it does not allow continuous paper flow.	1			
109	Curtis Middle School	A. Drinking Fountains	H. No drinking fountain provided for standing users L. Knee or toe clearance not provided	Drinking Fountain Next to 301	3	N/A	Priority 1	Program Access	Provide an additional drinking fountain for standing users or install a Hi-Lo drinking fountain. Provide knee and toe clearance, 27" min. high at drinking fountain for seated users. (Cost based on a new Hi-Lo fountain.)	1	Y	9/1/2025	FY26

18	Haynes Elementary School	H. Emergency Exit	N/A	Exit Door 16	Exterior	N/A	Priority 4	Enhanced Usability	Recommend providing accessible routes from all exit doors.	1			
19	Haynes Elementary School	H. Emergency Exit	B. Tactile sign not provided at exit C. Directional sign to accessible emergency exit not provided	Learning Center for Grades 4-5 Exit Door 17	1	15	Priority 2	Navigational Issue	Provide tactile exit signs with raised characters and braille at exit doors. Mount signs between 48"- 60" above the finished floor located on the latch side of the door. Provide a directional sign indicating the location of the nearest accessible emergency exit.	1			
20	Haynes Elementary School	H. Emergency Exit	B. Tactile sign not provided at exit C. Directional sign to accessible emergency exit not provided	Exit Door 18	1	16	Priority 2	Navigational Issue	Provide tactile exit signs with raised characters and braille at exit doors. Mount signs between 48"- 60" above the finished floor located on the latch side of the door. Provide a directional sign indicating the location of the nearest accessible emergency exit.	1			
21	Haynes Elementary School	H. Emergency Exit	B. Tactile sign not provided at exit C. Directional sign to accessible emergency exit not provided	Exit Doors From Classrooms	1	19 20	Priority 2	Navigational Issue	Provide tactile exit signs with raised characters and braille at exit doors. Mount signs between 48"- 60" above the finished floor located on the latch side of the door. Provide a directional sign indicating the location of the nearest accessible emergency exit.	2			
22	Haynes Elementary School	H. Emergency Exit	B. Tactile sign not provided at exit C. Directional sign to accessible emergency exit not provided	Exit Doors From Classrooms	1	21 22	Priority 2	Navigational Issue	Provide tactile exit signs with raised characters and braille at exit doors. Mount signs between 48"- 60" above the finished floor located on the latch side of the door. Provide a directional sign indicating the location of the nearest accessible emergency exit.	2			
23	Haynes Elementary School	H. Emergency Exit	B. Tactile sign not provided at exit C. Directional sign to accessible emergency exit not provided G. Maneuvering clearance(s) not provided	Grade 4 Exit Door 16	1	13	Priority 2	Navigational Issue	Provide tactile exit signs with raised characters and braille at exit doors. Mount signs between 48"- 60" above the finished floor located on the latch side of the door. Provide a directional sign indicating the location of the nearest accessible emergency exit. Relocate the table that is blocking the door.	1			
24	Haynes Elementary School	H. Emergency Exit	B. Tactile sign not provided at exit D. Illuminated Int. Symbol of Acc. not provided (MAAB)	Front Lobby	1	N/A	Priority 2	Navigational Issue	Provide tactile exit signs with raised characters and braille at exit doors. Mount signs between 48"- 60" above the finished floor located on the latch side of the door. Provide an illuminated sign with the International Symbol of Accessibility.	1	Y	7/17/2023	FY24
25	Haynes Elementary School	H. Emergency Exit	B. Tactile sign not provided at exit D. Illuminated Int. Symbol of Acc. not provided (MAAB)	Exit Door 6 by ESL	1	N/A	Priority 2	Navigational Issue	Provide tactile exit signs with raised characters and braille at exit doors. Mount signs between 48"- 60" above the finished floor located on the latch side of the door. Provide an illuminated sign with the International Symbol of Accessibility.	1	Y	7/17/2023	FY24
26	Haynes Elementary School	H. Emergency Exit	B. Tactile sign not provided at exit D. Illuminated Int. Symbol of Acc. not provided (MAAB)	Exit From Corridor by Rooms 22 and 23	1	N/A	Priority 2	Navigational Issue	Provide tactile exit signs with raised characters and braille at exit doors. Mount signs between 48"- 60" above the finished floor located on the latch side of the door. Provide an illuminated sign with the International Symbol of Accessibility.	1	Y	7/17/2023	FY24

27	Haynes Elementary School	H. Emergency Exit	B. Tactile sign not provided at exit D. Illuminated Int. Symbol of Acc. not provided (MAAB)	Exit Door 15 by Art Classroom	1	N/A	Priority 2	Navigational Issue	Provide tactile exit signs with raised characters and braille at exit doors. Mount signs between 48"- 60" above the finished floor located on the latch side of the door. Provide an illuminated sign with the International Symbol of Accessibility.	1	Y	7/17/2023	FY24
28	Haynes Elementary School	H. Emergency Exit	B. Tactile sign not provided at exit D. Illuminated Int. Symbol of Acc. not provided (MAAB)	Exit Door 14 From Gym	1	N/A	Priority 2	Navigational Issue	Provide tactile exit signs with raised characters and braille at exit doors. Mount signs between 48"- 60" above the finished floor located on the latch side of the door. Provide an illuminated sign with the International Symbol of Accessibility.	1	Y	7/17/2023	FY24
29	Haynes Elementary School	H. Emergency Exit	B. Tactile sign not provided at exit D. Illuminated Int. Symbol of Acc. not provided (MAAB)	Exit Door 13 From Gym	1	N/A	Priority 2	Navigational Issue	Provide tactile exit signs with raised characters and braille at exit doors. Mount signs between 48"- 60" above the finished floor located on the latch side of the door. Provide an illuminated sign with the International Symbol of Accessibility.	1	Y	7/17/2023	FY24
30	Haynes Elementary School	H. Emergency Exit	B. Tactile sign not provided at exit D. Illuminated Int. Symbol of Acc. not provided (MAAB)	Exit Door 12 From Gym	1	N/A	Priority 2	Navigational Issue	Provide tactile exit signs with raised characters and braille at exit doors. Mount signs between 48"- 60" above the finished floor located on the latch side of the door. Provide an illuminated sign with the International Symbol of Accessibility.	1	Y	7/17/2023	FY24
31	Haynes Elementary School	H. Emergency Exit	B. Tactile sign not provided at exit D. Illuminated Int. Symbol of Acc. not provided (MAAB)	Exit Door 9	1	N/A	Priority 2	Navigational Issue	Provide tactile exit signs with raised characters and braille at exit doors. Mount signs between 48"- 60" above the finished floor located on the latch side of the door. Provide an illuminated sign with the International Symbol of Accessibility.	1	Y	7/17/2023	FY24
32	Haynes Elementary School	H. Emergency Exit	B. Tactile sign not provided at exit D. Illuminated Int. Symbol of Acc. not provided (MAAB)	Exit Door 7	1	6	Priority 2	Navigational Issue	Provide tactile exit signs with raised characters and braille at exit doors. Mount signs between 48"- 60" above the finished floor located on the latch side of the door. Provide an illuminated sign with the International Symbol of Accessibility.	1	Y	7/17/2023	FY24
33	Haynes Elementary School	H. Emergency Exit	B. Tactile sign not provided at exit D. Illuminated Int. Symbol of Acc. not provided (MAAB)	Exit Door 8	1	7	Priority 2	Navigational Issue	Provide tactile exit signs with raised characters and braille at exit doors. Mount signs between 48"- 60" above the finished floor located on the latch side of the door. Provide an illuminated sign with the International Symbol of Accessibility.	1	Y	7/17/2023	FY24
34	Haynes Elementary School	H. Emergency Exit	B. Tactile sign not provided at exit D. Illuminated Int. Symbol of Acc. not provided (MAAB)	Partners Program (Grades 3-5) Egress Door 10	1	8	Priority 2	Navigational Issue	Provide tactile exit signs with raised characters and braille at exit doors. Mount signs between 48"- 60" above the finished floor located on the latch side of the door. Provide an illuminated sign with the International Symbol of Accessibility.	1	Y	7/17/2023	FY24
35	Haynes Elementary School	H. Emergency Exit	B. Tactile sign not provided at exit D. Illuminated Int. Symbol of Acc. not provided (MAAB) G. Maneuvering clearance(s) not provided	Partners Program (Grades K-2) Exit Door 11	1	9	Priority 2	Navigational Issue	Provide tactile exit signs with raised characters and braille at exit doors. Mount signs between 48"- 60" above the finished floor located on the latch side of the door. Provide an illuminated sign with the International Symbol of Accessibility. Relocate furniture.	1	Y	7/17/2023	FY24

36	Haynes Elementary School	H. Emergency Exit	B. Tactile sign not provided at exit D. Illuminated Int. Symbol of Acc. not provided (MAAB) L. Mat not securely attached	Exit Door 3 to the Parking Lot on the Side of the School	1	N/A	Priority 2	Navigational Issue	Provide tactile exit signs with raised characters and braille at exit doors. Mount signs between 48"- 60" above the finished floor located on the latch side of the door. Provide an illuminated sign with the International Symbol of Accessibility. Secure the mat.	1				
37	Haynes Elementary School	H. Emergency Exit	G. Maneuvering clearance(s) not provided	Partners Program (Grades 3-5) Egress Door 10	1	8	Priority 3	Additional Access	Relocate furniture that blocks access to the emergency exit.	1	Y	7/17/2023	FY24	
70	Haynes Elementary School	H. Signage	B. Raised characters not provided on sign D. Braille not provided on sign	Health Office Lobby From Corridor	1	N/A	Priority 2	Navigational Issue	Provide text with raised characters duplicated in braille on sign.	1				
71	Haynes Elementary School	H. Signage	B. Raised characters not provided on sign D. Braille not provided on sign	Partners Program (Grades 3-5)	1	8	Priority 2	Navigational Issue	Provide text with raised characters duplicated in braille on sign.	1				
72	Haynes Elementary School	H. Signage	Z. Sign lacks 18" min. by 18" min. clear floor space	Principal's Office	1	N/A	Priority 2	Navigational Issue	Relocate folder storage.	1				
95	Haynes Elementary School	D. Toilet Compartment	D. Door has malfunctioning self-closing hinge	Men's Toilet Room	1	N/A	Priority 3	Additional Access	Repair hinge.	1				
98	Haynes Elementary School	A. Single-User Toilet (Children)	A. Clearance at toilet < 72" clear deep	Partners Program (Grades 3-5) Toilet Room	1	8	Priority 3	Additional Access	Relocate stored items so that there is 72" clear deep at the toilet.	1				
99	Haynes Elementary School	A. Single-User Toilet (Children)	Q. Non-compliant toilet paper dispenser	Kindergarten Toilet Room	1	6	Priority 3	Additional Access	Relocate toilet paper dispenser so that it is between 14"- 19" above the floor and between 7"- 9" in front of the toilet. Ensure dispensers and other devices are not mounted above grab bars.	1	Y	11/6/2023	FY24	
100	Haynes Elementary School	A. Single-User Toilet (Children)	R. Coat hook not within reach range	Health Office Toilet Room	1	N/A	Priority 3	Additional Access	Lower hook so that it is no higher than 40" above the floor.	1	Y			
101	Haynes Elementary School	B. Toilet Compartment (Children)	R. Non-compliant toilet paper dispenser	Girls' Toilet Room Across From Auditorium	1	N/A	Priority 3	Additional Access	Relocate toilet paper dispenser so that it is between 14"- 19" above the floor and between 7"- 9" in front of the toilet. Ensure dispensers and other devices are not mounted above grab bars.	1	Y	11/6/2023	FY24	
102	Haynes Elementary School	B. Toilet Compartment (Children)	R. Non-compliant toilet paper dispenser U. Coat hook not within reach range	Women's Toilet Room by Lobby and Library	1	N/A	Priority 3	Additional Access	Relocate toilet paper dispenser so that it is between 14"- 19" above the floor and between 7"- 9" in front of the toilet. Ensure dispensers and other devices are not mounted above grab bars. Lower hook so that it is no higher than 44" for children ages 9-12. The other dimensions in the toilet room are built for this age range.	1	Y	11/6/2023	FY24	
103	Haynes Elementary School	B. Toilet Compartment (Children)	R. Non-compliant toilet paper dispenser U. Coat hook not within reach range	Men's Toilet Room	1	N/A	Priority 3	Additional Access	Relocate toilet paper dispenser so that it is between 14"- 19" above the floor and between 7"- 9" in front of the toilet. Ensure dispensers and other devices are not mounted above grab bars. Lower hook so that it is no higher than 44" for children ages 9-12. The other dimensions in the toilet room are built for this age range.	1	Y	11/3/2023	FY24	
104	Haynes Elementary School	B. Toilet Compartment (Children)	R. Non-compliant toilet paper dispenser U. Coat hook not within reach range	Boys' Toilet Room by Health Office	1	N/A	Priority 3	Additional Access	Relocate toilet paper dispenser so that it is between 14"- 19" above the floor and between 7"- 9" in front of the toilet. Ensure dispensers and other devices are not mounted above grab bars. Lower hook so that it is no higher than 44" for children ages 9-12. The rest of the dimensions in this toilet room are for this age group.	1	Y	11/6/2023	FY24	
110	Haynes Elementary School	D. Dispensers (Children)	A. Dispenser controls > 42" high	Boys' Toilet Room by Health Office	1	N/A	Priority 3	Additional Access	Relocate so the operable part is 42" max. above the finished floor.	1	Y	11/6/2023	FY24	
112	Haynes Elementary School	F. Toilet Paper Dispensers (Children)	C. Controls < 14" or > 17" (Ages 5 - 8) E. Dispenser located above grab bar	Partners Program (Grades K-2) Toilet Room	1	9	Priority 3	Additional Access	Relocate toilet paper dispenser so the operable part is between 14" and 17" above the finished floor. Relocate dispenser 1.5" minimum underneath the grab bar.	1	Y	11/6/2023	FY24	

113	Haynes Elementary School	F. Toilet Paper Dispensers (Children)	D. Controls < 17" or > 19" (Ages 9 - 12) E. Dispenser located above grab bar	Partners Program (Grades 3-5) Toilet Room	1	8	Priority 3	Additional Access	Relocate toilet paper dispenser so the operable part is between 14" and 17" above the finished floor. Relocate dispenser 1.5" minimum underneath the grab bar.	1			
114	Haynes Elementary School	A. Drinking Fountains	B. Clear floor space not provided C. Operable parts malfunctioning H. No drinking fountain provided for standing users	Exit From Corridor by Rooms 22 and 23	Exterior	N/A	Priority 3	Additional Access	Provide a 30" by 48" clear floor space positioned for a forward approach. (Cost estimate for 3' by 4' asphalt area.) Repair or replace drinking fountain to ensure operable parts are functioning. Provide an additional drinking fountain for standing users on an accessible route.	1	Y	11/6/2023	FY24
115	Haynes Elementary School	A. Drinking Fountains	H. No drinking fountain provided for standing users	Drinking Fountain	1	N/A	Priority 1	Program Access	Provide an additional drinking fountain for standing users.	1			
116	Haynes Elementary School	A. Drinking Fountains	H. No drinking fountain provided for standing users	Drinking Fountain by Gym	1	N/A	Priority 1	Program Access	Provide an additional drinking fountain for standing users.	1			
117	Haynes Elementary School	A. Drinking Fountains	H. No drinking fountain provided for standing users L. Knee or toe clearance not provided	Drinking Fountain	1	N/A	Priority 1	Program Access	Install a Hi-Lo drinking fountain.	1			
118	Haynes Elementary School	A. Drinking Fountains	L. Knee or toe clearance not provided	Drinking Fountain by Women's Toilet Room	1	N/A	Priority 1	Program Access	Provide a drinking fountain with knee and toe clearance, 27" min. high at drinking fountain for seated users. (Cost for a new low drinking fountain.)	1			

88	Loring Elementary School	D. Toilet Compartment	M. Flush control not on open side N. Non-compliant toilet paper dispenser	Men's Toilet Room	1	127	Priority 3	Additional Access	Provide the flush control on the open side of the toilet (transfer side). Relocate toilet paper so that it is 24" min. high, located under the grab bar, and between 7" and 9" from the front of the toilet. Replace dispenser as it does not allow continuous paper flow.	1			
95	Loring Elementary School	A. Single-User Toilet (Children)	B. Clearance at toilet < 60" clear wide	Single-User Toilet Room	1	109	Priority 3	Additional Access	Remove storage cabinet to provide a clear floor space that is 60" wide min.	1			
96	Loring Elementary School	A. Single-User Toilet (Children)	D. Flush control not on open side Q. Non-compliant toilet paper dispenser	Spanish Classroom Single-User Toilet Room	1	133	Priority 3	Additional Access	Move the flush control to the open side. Mount flush control between 20" - 30" above the floor. Relocate toilet paper dispenser so that it is between 14"- 19" above the floor and between 7"- 9" in front of the toilet. Ensure dispensers and other devices are not mounted above grab bars. Also relocate the paper towel and soap dispensers from above the grab bar.	1	Y	11/6/2023	FY24
97	Loring Elementary School	A. Single-User Toilet (Children)	Q. Non-compliant toilet paper dispenser	Kindergarten Single-User Toilet Room	1	135	Priority 3	Additional Access	Relocate toilet paper dispenser so that it is between 14"- 19" above the floor and between 7"- 9" in front of the toilet. Ensure dispensers and other devices are not mounted above grab bars./Replace dispenser as it does not allow continuous paper flow. Also relocate the paper towel and soap dispensers from above the grab bar.	1	Y	11/6/2023	FY24
98	Loring Elementary School	A. Single-User Toilet (Children)	Q. Non-compliant toilet paper dispenser Paper towel dispenser and tampon dispenser above grab bar.	Single-User Toilet Room	1	109	Priority 3	Additional Access	Relocate toilet paper dispenser so that it is between 14"- 19" above the floor and between 7"- 9" in front of the toilet. Ensure dispensers and other devices are not mounted above grab bars./Replace dispenser as it does not allow continuous paper flow. Relocate all dispensers so they are not located above the grab bars. (MAAB)	3	Y	11/6/2023	FY24
99	Loring Elementary School	B. Toilet Compartment (Children)	L. Side or rear grab bar < 25" or > 27" high (Ages 9 - 12) R. Non-compliant toilet paper dispenser	Girls' Toilet Room	2	N/A	Priority 3	Additional Access	Relocate side grab bar to 25"- 27" above the floor. Relocate toilet paper dispenser so that it is between 14"- 19" above the floor and between 7"- 9" in front of the toilet. Ensure dispensers and other devices are not mounted above grab bars./Replace dispenser as it does not allow continuous paper flow.	1	Y	11/6/2023	FY24
100	Loring Elementary School	B. Toilet Compartment (Children)	N. Flush control not on open side R. Non-compliant toilet paper dispenser	Boys' Toilet Room	1	147	Priority 3	Additional Access	Provide the flush control on the open side of the toilet (transfer side), no higher than 44". Relocate toilet paper dispenser so that it is between 14"- 19" above the floor and between 7"- 9" in front of the toilet. Ensure dispensers and other devices are not mounted above grab bars./Replace dispenser as it does not allow continuous paper flow.	1	Y	11/6/2023	FY24
101	Loring Elementary School	B. Toilet Compartment (Children)	N. Flush control not on open side R. Non-compliant toilet paper dispenser	Boys' Toilet Room	2	227	Priority 3	Additional Access	Provide the flush control on the open side of the toilet (transfer side), no higher than 44". Relocate toilet paper dispenser so that it is between 14"- 19" above the floor and between 7"- 9" in front of the toilet. Ensure dispensers and other devices are not mounted above grab bars./Replace dispenser as it does not allow continuous paper flow.	1	Y	11/6/2023	FY24

102	Loring Elementary School	B. Toilet Compartment (Children)	R. Non-compliant toilet paper dispenser	Boys' Toilet Room	1	167	Priority 3	Additional Access	Relocate toilet paper dispenser so that it is between 14"- 19" above the floor and between 7"- 9" in front of the toilet. Ensure dispensers and other devices are not mounted above grab bars./Replace dispenser as it does not allow continuous paper flow.	1	Y	11/6/2023	FY24
103	Loring Elementary School	B. Toilet Compartment (Children)	R. Non-compliant toilet paper dispenser	Girls' Toilet Room	1	168	Priority 3	Additional Access	Relocate toilet paper dispenser so that it is between 14"- 19" above the floor and between 7"- 9" in front of the toilet. Ensure dispensers and other devices are not mounted above grab bars./Replace dispenser as it does not allow continuous paper flow.	1	Y	11/6/2023	FY24
104	Loring Elementary School	B. Toilet Compartment (Children)	R. Non-compliant toilet paper dispenser	Girls' Toilet Room	1	146	Priority 3	Additional Access	Relocate toilet paper dispenser so that it is between 14"- 19" above the floor and between 7"- 9" in front of the toilet. Ensure dispensers and other devices are not mounted above grab bars./Replace dispenser as it does not allow continuous paper flow.	1	Y	11/6/2023	FY24
105	Loring Elementary School	B. Toilet Compartment (Children)	R. Non-compliant toilet paper dispenser	Women's Toilet Room	1	N/A	Priority 3	Additional Access	Relocate toilet paper dispenser so that it is between 14"- 19" above the floor and between 7"- 9" in front of the toilet. Ensure dispensers and other devices are not mounted above grab bars. Replace dispenser as it does not allow continuous paper flow.	1	Y	11/6/2023	FY24
106	Loring Elementary School	B. Toilet Compartment (Children)	R. Non-compliant toilet paper dispenser	Boys' Toilet Room	2	241	Priority 3	Additional Access	Relocate toilet paper dispenser so that it is between 14"- 19" above the floor and between 7"- 9" in front of the toilet. Ensure dispensers and other devices are not mounted above grab bars./Replace dispenser as it does not allow continuous paper flow.	1	Y	11/6/2023	FY24
107	Loring Elementary School	B. Toilet Compartment (Children)	R. Non-compliant toilet paper dispenser	Girls' Toilet Room	2	226	Priority 3	Additional Access	Relocate toilet paper dispenser so that it is between 14"- 19" above the floor and between 7"- 9" in front of the toilet. Ensure dispensers and other devices are not mounted above grab bars./Replace dispenser as it does not allow continuous paper flow.	1	Y	11/6/2023	FY24
119	Loring Elementary School	D. Dispensers (Children)	D. Dispenser is a protruding object	Girls' Toilet Room	1	168	Priority 3	Additional Access	Relocate dispenser out of the circulation path or place a cane-detectable barrier under the dispenser.	1	Y	11/6/2023	FY24
120	Loring Elementary School	D. Dispensers (Children)	D. Dispenser is a protruding object	Boys' Toilet Room	1	147	Priority 3	Additional Access	Relocate paper towel dispenser out of the circulation path or place a cane-detectable barrier under the dispenser.	1	Y	11/6/2023	FY24
121	Loring Elementary School	D. Dispensers (Children)	D. Dispenser is a protruding object	Girls' Toilet Room	1	146	Priority 3	Additional Access	Relocate dispenser out of the circulation path or place a cane-detectable barrier under the dispenser.	1	Y	11/6/2023	FY24
123	Loring Elementary School	A. Drinking Fountains	H. No drinking fountain provided for standing users	Drinking Fountain	1	N/A	Priority 1	Program Access	Provide an additional drinking fountain for standing users or install a Hi-Lo drinking fountain.	1			
124	Loring Elementary School	A. Drinking Fountains	H. No drinking fountain provided for standing users	Hallway	1	147	Priority 1	Program Access	Provide an additional drinking fountain for standing users or install a Hi-Lo drinking fountain.	1			
125	Loring Elementary School	A. Drinking Fountains	H. No drinking fountain provided for standing users	Drinking Fountain	2	N/A	Priority 1	Program Access	Provide an additional drinking fountain for standing users or install a Hi-Lo drinking fountain.	1			

18	Nixon Elementary School	H. Emergency Exit	B. Tactile sign not provided at exit C. Directional sign to accessible emergency exit not provided	Egress Door 6	1	N/A	Priority 2	Navigational Issue	Provide tactile exit signs with raised characters and braille at exit doors. Mount signs between 48"- 60" above the finished floor located on the latch side of the door. Provide a directional sign indicating the location of the nearest accessible emergency exit.	1	Y	8/1/2022	FY23
19	Nixon Elementary School	H. Emergency Exit	B. Tactile sign not provided at exit D. Illuminated Int. Symbol of Acc. not provided (MAAB)	Main Entrance Door 1 (Egress)	1	N/A	Priority 2	Navigational Issue	Provide tactile exit signs with raised characters and braille at exit doors. Mount signs between 48"- 60" above the finished floor located on the latch side of the door. Provide an illuminated sign with the International Symbol of Accessibility.	1	Y	8/1/2022	FY23
20	Nixon Elementary School	H. Emergency Exit	B. Tactile sign not provided at exit D. Illuminated Int. Symbol of Acc. not provided (MAAB)	Egress Door 7	1	N/A	Priority 2	Navigational Issue	Provide tactile exit signs with raised characters and braille at exit doors. Mount signs between 48"- 60" above the finished floor located on the latch side of the door. Provide an illuminated sign with the International Symbol of Accessibility.	1	Y	8/1/2022	FY23
21	Nixon Elementary School	H. Emergency Exit	B. Tactile sign not provided at exit D. Illuminated Int. Symbol of Acc. not provided (MAAB)	Egress Door 2	1	N/A	Priority 2	Navigational Issue	Provide tactile exit signs with raised characters and braille at exit doors. Mount signs between 48"- 60" above the finished floor located on the latch side of the door. Provide an illuminated sign with the International Symbol of Accessibility.	1	Y	8/1/2022	FY23
22	Nixon Elementary School	H. Emergency Exit	B. Tactile sign not provided at exit D. Illuminated Int. Symbol of Acc. not provided (MAAB)	Egress Door 13	1	N/A	Priority 2	Navigational Issue	Provide tactile exit signs with raised characters and braille at exit doors. Mount signs between 48"- 60" above the finished floor located on the latch side of the door. Provide an illuminated sign with the International Symbol of Accessibility.	1	Y	8/1/2022	FY23
23	Nixon Elementary School	H. Emergency Exit	B. Tactile sign not provided at exit D. Illuminated Int. Symbol of Acc. not provided (MAAB)	Egress Door 8	1	N/A	Priority 2	Navigational Issue	Provide tactile exit signs with raised characters and braille at exit doors. Mount signs between 48"- 60" above the finished floor located on the latch side of the door. Provide an illuminated sign with the International Symbol of Accessibility.	1	Y	8/1/2022	FY23
24	Nixon Elementary School	H. Emergency Exit	B. Tactile sign not provided at exit D. Illuminated Int. Symbol of Acc. not provided (MAAB)	Gym Egress Door 9	1	16	Priority 2	Navigational Issue	Provide tactile exit signs with raised characters and braille at exit doors. Mount signs between 48"- 60" above the finished floor located on the latch side of the door. Provide an illuminated sign with the International Symbol of Accessibility.	1	Y	8/1/2022	FY23
25	Nixon Elementary School	H. Emergency Exit	B. Tactile sign not provided at exit D. Illuminated Int. Symbol of Acc. not provided (MAAB)	Gym Egress Door 10	1	16	Priority 2	Navigational Issue	Provide tactile exit signs with raised characters and braille at exit doors. Mount signs between 48"- 60" above the finished floor located on the latch side of the door. Provide an illuminated sign with the International Symbol of Accessibility.	1	Y	8/1/2022	FY23
26	Nixon Elementary School	H. Emergency Exit	B. Tactile sign not provided at exit D. Illuminated Int. Symbol of Acc. not provided (MAAB)	Corridor Exit 12 by Office 19	1	19	Priority 2	Navigational Issue	Provide tactile exit signs with raised characters and braille at exit doors. Mount signs between 48"- 60" above the finished floor located on the latch side of the door. Provide an illuminated sign with the International Symbol of Accessibility.	1	Y	8/1/2022	FY23
27	Nixon Elementary School	H. Emergency Exit	R. Door requires > 15 lbs. of force to open	Corridor Exit 12 by Office 19	1	19	Priority 3	Additional Access	Adjust closers of exterior doors so doors do not require more than 15 pounds of force.	1	Y	8/1/2022	FY23

28	Nixon Elementary School	H. Emergency Exit	R. Door requires > 15 lbs. of force to open	Egress Door 8	Exterior	N/A	Priority 3	Additional Access	Adjust closers of exterior doors so doors do not require more than 15 pounds of force.	1			
39	Nixon Elementary School	H. Signage	C. Raised characters < 48" or > 60" above ground	Gym	1	16	Priority 2	Navigational Issue	Mount signs so that the baseline of the lowest tactile character is 48" min. above finished floor and the baseline of the highest tactile character is 60" max. above the finished floor.	1			
40	Nixon Elementary School	H. Signage	G. Sign not located on the latch side of the door	Cafeteria	1	N/A	Priority 2	Navigational Issue	Locate sign at permanent rooms alongside the door on the latch side.	1	Y	8/26/2024	FY24
41	Nixon Elementary School	H. Signage	G. Sign not located on the latch side of the door	Girls' Toilet Room Near the Gym	1	N/A	Priority 2	Navigational Issue	Locate sign at permanent rooms alongside the door on the latch side.	1			
70	Nixon Elementary School	D. Toilet Compartment	C. Door has non-compliant hardware D. Door has malfunctioning self-closing hinge	Girls' Toilet Room by the Gym	1	N/A	Priority 3	Additional Access	Provide hardware that can be operable with one hand and not require tight grasping, pinching, or twisting of the wrist. Repair hinge.	1			
71	Nixon Elementary School	D. Toilet Compartment	D. Door has malfunctioning self-closing hinge	Boys' Toilet Room by the Gym	1	N/A	Priority 3	Additional Access	Repair hinge.	1			
72	Nixon Elementary School	D. Toilet Compartment	D. Door has malfunctioning self-closing hinge	Girls' Toilet Room Near Classroom 8	1	N/A	Priority 3	Additional Access	Repair hinge.	1			
73	Nixon Elementary School	D. Toilet Compartment	D. Door has malfunctioning self-closing hinge	Boys' Toilet Room Near Classroom 8	1	N/A	Priority 3	Additional Access	Repair hinge.	1			
74	Nixon Elementary School	D. Toilet Compartment	M. Flush control not on open side	Girls' Toilet Room Near Classroom 8	1	N/A	Priority 3	Additional Access	Provide the flush control on the open side of the toilet (transfer side).	1			
75	Nixon Elementary School	D. Toilet Compartment	M. Flush control not on open side N. Non-compliant toilet paper dispenser	Girls' Toilet Room by the Gym	1	N/A	Priority 3	Additional Access	Provide the flush control on the open side of the toilet (transfer side). Relocate toilet paper so that it is 24" min. high, located under the grab bar, and between 7" and 9" from the front of the toilet.	1			
76	Nixon Elementary School	D. Toilet Compartment	N. Non-compliant toilet paper dispenser	Boys' Toilet Room by the Gym	1	N/A	Priority 3	Additional Access	Relocate toilet paper so that it is 24" min. high, located under the grab bar, and between 7" and 9" from the front of the toilet.	1			
81	Nixon Elementary School	A. Single-User Toilet (Children)	F. Toilet seat < 12" or > 15" high (K - 3) L. Side or rear grab bar < 42" long Q. Non-compliant toilet paper dispenser	Kindergarten Toilet Room	1	N/A	Priority 3	Additional Access	Install a toilet with a seat between 12"-15" high above the finished floor. Provide a rear wall grab bar that is 42" long located 6" max. from the interior corner. Relocate toilet paper dispenser so that it is between 14"-19" above the floor and between 7"-9" in front of the toilet. Ensure dispensers and other devices are not mounted above grab bars.	1	Y	11/6/2023	FY24
82	Nixon Elementary School	B. Toilet Compartment (Children)	B. Door with non-compliant hardware U. Coat hook not within reach range	Boys' Toilet Room by Room 27	1	N/A	Priority 3	Additional Access	Provide hardware that can be operable with one hand and not require tight grasping, pinching, or twisting of the wrist. Lower hook so that it is no higher than 44" for children ages 9-12.	1	Y	8/1/2022	FY23
83	Nixon Elementary School	B. Toilet Compartment (Children)	L. Side or rear grab bar < 25" or > 27" high (Ages 9 - 12) R. Non-compliant toilet paper dispenser	Boys' Toilet Room by Room 27	1	N/A	Priority 3	Additional Access	Relocate both grab bars to 25"-27" above the floor. Relocate toilet paper dispenser so that it is between 14"-19" above the floor and between 7"-9" in front of the toilet. Ensure dispensers and other devices are not mounted above grab bars.	1	Y	8/1/2022	FY23
84	Nixon Elementary School	B. Toilet Compartment (Children)	R. Non-compliant toilet paper dispenser S. Clearance at toilet < 60" clear width	Girls' Toilet Room by Room 27	1	N/A	Priority 3	Additional Access	Relocate toilet paper dispenser so that it is between 14"-19" above the floor and between 7"-9" in front of the toilet. Ensure dispensers and other devices are not mounted above grab bars. Remove desk.	1	Y	8/1/2022	FY23
89	Nixon Elementary School	A. Drinking Fountains	H. No drinking fountain provided for standing users	Drinking Fountain Next to Boys' Toilet Room by Room 27	1	N/A	Priority 1	Program Access	Provide an additional drinking fountain for standing users.	1			
90	Nixon Elementary School	A. Drinking Fountains	H. No drinking fountain provided for standing users	Fountain Next to Gym	1	N/A	Priority 1	Program Access	Provide an additional drinking fountain for standing users.	1			
91	Nixon Elementary School	A. Drinking Fountains	H. No drinking fountain provided for standing users	Drinking Fountain Between Toilet Rooms Near Classroom 8	1	N/A	Priority 1	Program Access	Provide an additional drinking fountain for standing users.	1			
92	Nixon Elementary School	A. Drinking Fountains	H. No drinking fountain provided for standing users	Fountain Next to Cafeteria	1	N/A	Priority 1	Program Access	Provide an additional drinking fountain for standing users.	1			
93	Nixon Elementary School	A. Drinking Fountains	H. No drinking fountain provided for standing users	Drinking Fountain by Kitchen Area	1	N/A	Priority 1	Program Access	Install a Hi-Lo drinking fountain.	1			
94	Nixon Elementary School	A. Drinking Fountains	H. No drinking fountain provided for standing users	Drinking Fountain at Playground	Exterior	N/A	Priority 1	Program Access	Provide an additional drinking fountain for standing users.	1			

41	Peter Noyes Elementary School	H. Signage	A. Signage is not provided	Learning Studio	3	39	Priority 1	Program Access	Provide designation signage with the words, "Learning Studio" Current sign says, "Computer Lab" Locate compliant signage alongside the door on the latch side.	1			
42	Peter Noyes Elementary School	H. Signage	A. Signage is not provided	Occupational Therapy Office	4	N/A	Priority 1	Program Access	Locate compliant signage with raised characters and braille alongside the door on the latch side.	1			
43	Peter Noyes Elementary School	H. Signage	B. Raised characters not provided on sign D. Braille not provided on sign	School Psychologist	3	N/A	Priority 2	Navigational Issue	Provide text with raised characters duplicated in braille on sign.	1			
44	Peter Noyes Elementary School	H. Signage	B. Raised characters not provided on sign D. Braille not provided on sign F. Visual characters < 40" above ground G. Sign not located on the latch side of the door	Grade 5	4	10	Priority 2	Navigational Issue	Provide text with raised characters duplicated in braille on sign. Provide braille on sign. Mount visual sign so that the baseline of the lowest character is 40" min. above the finished floor. Locate sign at permanent rooms alongside the door on the latch side.	10			
45	Peter Noyes Elementary School	H. Signage	C. Raised characters < 48" or > 60" above ground	Inaccessible Toilet Rooms	1	N/A	Priority 2	Navigational Issue	Mount signs so that the baseline of the lowest tactile character is 48" min. above finished floor and the baseline of the highest tactile character is 60" max. above the finished floor.	2			
46	Peter Noyes Elementary School	H. Signage	G. Sign not located on the latch side of the door	Literacy Center	3	34	Priority 2	Navigational Issue	Locate sign at permanent rooms alongside the door on the latch side.	1			
58	Peter Noyes Elementary School	A. Single-User Toilet (Children)	A. Clearance at toilet < 72" clear deep F. Toilet seat < 12" or > 15" high (K - 3) J. Centerline < 12" or > 15" (K - 3) N. Side or rear grab bar < 20" or > 25" high (K - 3) Q. Non-compliant toilet paper dispenser	Gender Neutral Toilet Room	2	N/A	Priority 3	Additional Access	Renovate toilet room to provide a clear floor space that is 72" deep min. by moving toilet to back wall. Install a toilet with a seat between 12"- 15" high above the finished floor. Relocate toilet so that the centerline is between 12" and 15" from the side wall. Locate grab bar between 20"- 25" above the floor. Relocate toilet paper dispenser so that it is not mounted above grab bars.	1			
59	Peter Noyes Elementary School	A. Single-User Toilet (Children)	B. Clearance at toilet < 60" clear wide	Office - Nurse's Room	3	N/A	Priority 3	Additional Access	Remove desk from transfer clear floor space at toilet.	1			
60	Peter Noyes Elementary School	A. Single-User Toilet (Children)	D. Flush control not on open side Q. Non-compliant toilet paper dispenser	Girls' Toilet Room	3	N/A	Priority 3	Additional Access	Move the flush control to the open side. Mount flush control between 20" - 30" above the floor. Relocate toilet paper dispenser so that it is between 14"- 19" above the floor and between 7"- 9" in front of the toilet. Ensure dispensers and other devices are not mounted above grab bars./Replace dispenser as it does not allow continuous paper flow.	1			
61	Peter Noyes Elementary School	A. Single-User Toilet (Children)	P. Side or rear grab bar not provided Q. Non-compliant toilet paper dispenser	Pre-K Classroom	3	25	Priority 1	Program Access	Provide one grab bar on the rear wall. Relocate toilet paper dispenser so that it is between 14"- 19" above the floor and between 7"- 9" in front of the toilet. Ensure dispensers and other devices are not mounted above grab bars./Replace dispenser as it does not allow continuous paper flow.	1			
62	Peter Noyes Elementary School	A. Single-User Toilet (Children)	Q. Non-compliant toilet paper dispenser	Office - Nurse's Room	3	N/A	Priority 3	Additional Access	Relocate toilet paper dispenser so that it is between 14"- 19" above the floor and between 7"- 9" in front of the toilet. Ensure dispensers and other devices are not mounted above grab bars./Replace dispenser as it does not allow continuous paper flow.	1			

63	Peter Noyes Elementary School	B. Toilet Compartment (Children)	F. Toilet seat < 12" or > 15" high (Ages 5 - 8) N. Flush control not on open side P. Centerline < 12" or > 15" (Ages 5 - 8) R. Non-compliant toilet paper dispenser	Boys' Toilet Room	4	N/A	Priority 3	Additional Access	Install a toilet with a seat between 12"-15" high above the finished floor. Provide the flush control on the open side of the toilet (transfer side), no higher than 44". Relocate toilet so that the centerline is between 12" and 15" from the side wall. Relocate toilet paper dispenser so that it is between 14"- 19" above the floor and between 7"- 9" in front of the toilet below grab bar.	1			
64	Peter Noyes Elementary School	B. Toilet Compartment (Children)	N. Flush control not on open side P. Centerline < 12" or > 15" (Ages 5 - 8) R. Non-compliant toilet paper dispenser	Girls' Toilet Room	1	N/A	Priority 3	Additional Access	Provide the flush control on the open side of the toilet (transfer side), no higher than 44". Relocate toilet so that the centerline is between 12" and 15" from the side wall. Relocate toilet paper dispenser so that it is between 14"- 19" above the floor and between 7"- 9" in front of the toilet. Ensure dispensers and other devices are not mounted above grab bars.	1			
65	Peter Noyes Elementary School	B. Toilet Compartment (Children)	N. Flush control not on open side R. Non-compliant toilet paper dispenser	Boys' Toilet Room	2	N/A	Priority 3	Additional Access	Provide the flush control on the open side of the toilet (transfer side), no higher than 44". Relocate toilet paper dispenser so that it is between 14"- 19" above the floor and between 7"- 9" in front of the toilet. Ensure dispensers and other devices are not mounted above grab bars. / Replace dispenser as it does not allow continuous paper flow.	1			
66	Peter Noyes Elementary School	B. Toilet Compartment (Children)	P. Centerline < 12" or > 15" (Ages 5 - 8) R. Non-compliant toilet paper dispenser	Girls' Toilet Room	2	N/A	Priority 3	Additional Access	Relocate toilet so that the centerline is between 12" and 15" from the side wall. Relocate toilet paper dispenser so that it is between 14"- 19" above the floor and between 7"- 9" in front of the toilet. Ensure dispensers and other devices are not mounted above grab bars.	1			
67	Peter Noyes Elementary School	B. Toilet Compartment (Children)	R. Non-compliant toilet paper dispenser	Girls' Toilet Room	4	N/A	Priority 3	Additional Access	Relocate toilet paper dispenser so that it is between 14"- 19" above the floor and between 7"- 9" in front of the toilet. Ensure dispensers and other devices are not mounted above grab bars./Replace dispenser as it does not allow continuous paper flow.	1			
68	Peter Noyes Elementary School	B. Toilet Compartment (Children)	R. Non-compliant toilet paper dispenser	Boys' Toilet Room	3	N/A	Priority 3	Additional Access	Relocate toilet paper dispenser so that it is between 14"- 19" above the floor and between 7"- 9" in front of the toilet. Ensure dispensers and other devices are not mounted above grab bars./Replace dispenser as it does not allow continuous paper flow.	1			
69	Peter Noyes Elementary School	B. Toilet Compartment (Children)	R. Non-compliant toilet paper dispenser	Boys' Toilet Room	1	N/A	Priority 3	Additional Access	Relocate toilet paper dispenser so that it is between 14"- 19" above the floor and between 7"- 9" in front of the toilet. Ensure dispensers and other devices are not mounted above grab bars./Replace dispenser as it does not allow continuous paper flow.	1			
80	Peter Noyes Elementary School	D. Dispensers (Children)	A. Dispenser controls > 42" high D. Dispenser is a protruding object	Girls' Toilet Room	2	N/A	Priority 3	Additional Access	Relocate so the operable part of the paper towel dispenser is 42" max. above the finished floor. Relocate dispenser out of the circulation path or provide a cane-detectible-	1	Y	8/1/2022	FY23
81	Peter Noyes Elementary School	D. Dispensers (Children)	D. Dispenser is a protruding object	Boys' Toilet Room	4	N/A	Priority 3	Additional Access	Relocate dispenser out of the circulation path or provide a cane-detectible	1			
82	Peter Noyes Elementary School	D. Dispensers (Children)	D. Dispenser is a protruding object	Girls' Toilet Room	3	N/A	Priority 3	Additional Access	Relocate dispenser out of the circulation path or provide a cane-detectible	1			
83	Peter Noyes Elementary School	A. Drinking Fountains	H. No drinking fountain provided for standing users	Near Toilet Rooms	3	N/A	Priority 1	Program Access	Provide an additional drinking fountain for standing users or install a Hi-Lo drinking fountain.	1			

84	Peter Noyes Elementary School	A. Drinking Fountains	H. No drinking fountain provided for standing users	Cafeteria	1	N/A	Priority 1	Program Access	Provide an additional drinking fountain for standing users or install a Hi-Lo drinking fountain.	1			
85	Peter Noyes Elementary School	A. Drinking Fountains	H. No drinking fountain provided for standing users	By Toilet Rooms	1	N/A	Priority 1	Program Access	Provide an additional drinking fountain for standing users or install a Hi-Lo drinking fountain.	1			
86	Peter Noyes Elementary School	A. Drinking Fountains	H. No drinking fountain provided for standing users L. Knee or toe clearance not provided	Near Toilet Rooms	4	N/A	Priority 1	Program Access	Provide an additional drinking fountain for standing users or install a Hi-Lo drinking fountain. Provide knee and toe clearance, 27" min. high at drinking fountain for seated users. (Cost based on a new Hi-Lo drinking fountain.)	1			
87	Peter Noyes Elementary School	A. Drinking Fountains	H. No drinking fountain provided for standing users L. Knee or toe clearance not provided	Near Toilet Rooms	2	N/A	Priority 1	Program Access	Provide an additional drinking fountain for standing users or install a Hi-Lo drinking fountain. Provide knee and toe clearance, 27" min. high at drinking fountain for seated users. (Cost based on a new Hi-Lo drinking fountain.)	1			
88	Peter Noyes Elementary School	A. Drinking Fountains	L. Knee or toe clearance not provided H. No drinking fountain provided for standing users	Hallway to Pre-K Classrooms	3	N/A	Priority 1	Program Access	Provide an additional drinking fountain for standing users or install a Hi-Lo drinking fountain. Provide knee and toe clearance, 27" min. high at drinking fountain for seated users. (Cost based on a new Hi-Lo drinking fountain.)	1			